

## Certificate of constancy of performance

0036 CPR 91400 002

In compliance with Regulation 305/2011/EU of the European Parliament and of the Council of 9 March 2011 (the Construction Products Regulation or CPR), this certificate applies to the construction product

# Voice alarm control and indicating equipment for fire detection and fire alarm systems INTRON-X /FA

for details of classification see page 2

placed on the market under the name or trade mark of

INDUSTRONIC
Industrie-Electronic GmbH & Co. KG
Carl-Jacob-Kolb-Weg 1
97877 Wertheim

and produced in the manufacturing plant

INDUSTRONIC Industrie-Electronic GmbH & Co. KG Carl-Jacob-Kolb-Weg 1 97877 Wertheim

This certificate attests that all provisions concerning the assessment and verification of constancy of performance described in Annex ZA of the standard

DIN EN 54-16: 2008-06

under system 1 for the performance set out in this certificate are applied and that the factory production control conducted by the manufacturer is assessed to ensure the constancy of performance of the construction product.

This certificate was first issued on 2023-02-13 and will remain valid as long as neither the harmonised standard, the production product, the AVCP methods nor the manufacturing conditions in the plant are modified significantly, unless suspended or withdrawn by the notified product certification body.

Munich, 2023-02-13

Johannes Steiglechner Leiter Zertifizierungsstelle Bauprodukte

This certificate is the english version of the original german certificate. In any case of doubt the german version is binding. TÜV SÜD INDUSTRIE SERVICE GMBH, WESTENDSTRASSE 199, 80686 MUNICH, GERMANY

#### Page 2 of certificate no.

#### 0036 CPR 91400 002



#### Product characteristics

Voice alarm control and indicating equipment for fire detection and fire alarm systems in buildings

INTRON-X /FA Type

#### Optional features with requirements

- Phased evacuation
  - Manual silencing of the voice alarm condition
  - Manual reset of voice alarm condition
- output to fire alarm devices
- voice alarm condition output
- indication of faults related to the transmission path on the CIE
- indication of faults related to voice alarm zones (only NPA-amplifier)
- voice alarm manual control
- emergency microphones
- redundant power amplifiers

#### Technical data of integrated power supply

- Mains voltage (AC) 230 V (+10/-15)% / 50 Hz
- Amplifier output rating (constant)

250 DVE 13 Type 1 x 250 W Туре 500 DVE 13 2 x 250 W 300 NPA 1x 1 x 300 W Type 300 NPA 2x 2 x 150 W (±2%) Type 600 NPA 2x 2 x 300 W Type 1 x 300 W + 2 x 150 W (±2%) Type 600 NPA 3x 600 NPA 4x 4 x 150 W (±2%) Type

This equipment has to be mounted and installed according to the following documentation of the manufacturer

- Wiring instructions Dok. Nr. GDL-330-001-403
- Initial operation and fault correction, Dok. Nr. GDL-330-001-412

This certificate is the english version of the original german certificate. In any case of doubt the german version is binding. TÜV SÜD INDUSTRIE SERVICE GMBH, WESTENDSTRASSE 199, 80686 MUNICH, GERMANY



### **Declaration of Performance**

## According to Construction Products Regulation (EU) No. 305/2011 Document no. DOP-330-002-002

1. Unique identification code of the product type:

Voice alarm control and indicating equipment according to EN54-16, of type INTRON-X /FA

2. Intended use in accordance with the applicable harmonized technical specification:

Voice alarm control and indicating equipment for fire detection and fire alarm systems in buildings

3. Manufacturer:

INDUSTRONIC® Industrie-Electronic GmbH & Co. KG Carl-Jacob-Kolb-Weg 1 97877 Wertheim / Germany

4. Address of the authorized representative:

Not applicable

5. System of assessment and verification of constancy of performance as set out in Annex V:

System 1

6. Harmonized standard:

DIN EN 54-16:2008

7. Notified body:

TÜV SÜD Industrie Service GmbH Notified body number 0036

performed type testing and initial inspection of the manufacturing plant and the factory production control with continuous surveillance, assessment and approval of the factory production control under system 1 and issued a certificate of constancy of performance:

0036 - CPR - 91400 002 für die INTRON-X /FA

8. Declared performance:

Essential characteristics	Performance	Harmonized technical specification
Performance under fire condition		,
- General requirements	Passed	EN54-16:2008 clause 4
<ul> <li>General requirements for indications</li> </ul>	Passed	EN54-16:2008 clause 5
- Voice alarm condition	Passed	EN54-16:2008 clause 7



Doc. no. DOP-330-002-002/IX • V01 • EN • 20.02.2023



- Emergency microphone(s) (option)	Passed	EN54-16:2008 clause 12
- Voice alarm manual control	Passed	EN54-16:2008 clause 10
- Signal-to-noise ratio	Passed	EN54-16:2008 clause 16.5
- Frequency response of VACIE without microphone(s)	Passed	EN54-16:2008 clause 16.6
- Frequency response of VACIE with microphone(s)	Passed	EN54-16:2008 clause 16.7
Response delay (response time to alarm)		
- Reception and processing of fire signals	Passed	EN54-16:2008 clause 7.1
- Indication of the voice alarm condition	Passed	EN54-16:2008 clause 7.2
- Audible warning (option)	NPD	EN54-16:2008 clause 7.3
- Delays to entering the voice alarm condition (option)	NPD	EN54-16:2008 clause 7.4
- Phased evacuation (option)	Passed	EN54-16:2008 clause 7.5
- Silencing of the voice alarm condition (partly optional)	Passed	EN54-16:2008 clause 7.6
- Reset of the voice alarm condition (partly optional)	Passed	EN54-16:2008 clause 7.7
- Output to fire alarm devices (option)	Passed	EN54-16:2008 clause 7.8
- Voice alarm condition output (option)	Passed	EN54-16:2008 clause 7.9
- Voice alarm manual control	Passed	EN54-16:2008 clause 12
Operational reliability		
- General requirements	Passed	EN54-16:2008 clause 4
- General requirements for indications	Passed	EN54-16:2008 clause 5
- Quiescent condition	Passed	EN54-16:2008 clause 6
- Voice alarm condition	Passed	EN54-16:2008 clause 7
- Fault warning condition	Passed	EN54-16:2008 clause 8
- Indication of faults related to the transmission path to the CIE (option)	Passed	EN54-16:2008 clause 8.3
- Indication of faults related to voice alarm zones (option)	Passed	EN54-16:2008 clause 8.4
- Disablement condition (option)	NPD	EN54-16:2008 clause 9
- Voice alarm manual control	Passed	EN54-16:2008 clause 10
- Interface to external control device(s) (option)	NPD	EN54-16:2008 clause 11
- Voice alarm manual control	Passed	EN54-16:2008 clause 12
- Design requirements (partly optional)	Passed	EN54-16:2008 clause 13
- Additional design requirements for software controlled VACIE	Passed	EN54-16:2008 clause 14
- Marking	Passed	EN54-16:2008 clause 15
Durability of operational reliability, temperature resistance		
- Output power	Passed	EN54-16:2008 clause 16.4
- Cold (operational)	Passed	EN54-16:2008 clause 16.8
Durability of operational reliability, impact and vibration resistance		
- Impact (operational)		
- Vibration, sinusoidal (operational)	Passed	EN54-16:2008 clause 16.11
- Vibration, sinusoidal (endurance)	Passed	EN54-16:2008 clause 16.12
201201212121212121212121212121212121212	Passed	EN54-16:2008 clause 16.13
Durability of operational reliability, electrical stability		
- Supply voltage variation	Passed	EN54-16:2008 clause 16.14
- Electromagnetic compatibility (EMC), immunity tests (operational)	Passed	EN54-16:2008 clause 16.15
Durability of operational reliability, humidity resistance	. 45004	2.10 1 10.2000 ciau3e 10.13
- Damp heat, steady state (operational)	Passed	EN54-16:2008 clause 16.9
- Damp heat, steady state (endurance)	Passed	EN54-16:2008 clause 16.10
Barry riods otoday otato (oridaranoo)	1 43364	LINOT 10.2000 Clause 10.10

The performance of the product identified above is in conformity with the set of declared performance(s) under section 8. This declaration of performance is issued, in accordance with Regulation (EU) No. 305/2011, under the sole responsibility of the manufacturer identified above.

Wertheim, February 2023

Wolfgang Stallmeyer

President



Doc. no. DOP-330-002-002/IX • V01 • EN • 20.02.2023



### **EU - DECLARATION OF CONFORMITY**

The voice alarm control and indicating equipment for fire detection and fire alarm systems of type

INTRON-X /FA

has been designed, constructed and manufactured in sole responsibility by

INDUSTRONIC®
Industrie-Electronic GmbH & Co. KG
Carl-Jacob-Kolb-Weg 1
97877 Wertheim / Germany

in compliance with the EU directives

2014/35/EU - Low Voltage equipment

2014/30/EU - Electromagnetic compatibility (EMC)

menze

applying the following harmonised standards:

Electromagnetic compatibility

EN61000-6-4:2007 + A1:2011, EN50130-4:2003

Safety of information technology equipment

EN62368-1:2014/AC:2015

This declaration certifies the compliance with the mentioned directives. It is no assertion of other properties.

Wertheim, February 2023

Wolfgang Stallmeyer

President



Doc. no. DEC-330-002-002/IX • V01 • EN • 20.02.2023